

Q&A

1. *Forklift use, will the contractor be able to use the unit's forklift to remove the existing boiler and install the new boiler?* After taking measurements of the door threshold, it was determined that the mast on the base forklift would not fit through the door threshold. It is advised that the contractor would have to use their own equipment for removal and installation.
2. *Will the unit provide the lock out/tag out of all electrical components that are required during the removal and installation?* The unit MK's or EM's will conduct the lock out/tag out during the construction.