

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT			1. CONTRACT ID CODE	PAGE 1	OF PAGES 3
2. AMENDMENT/MODIFICATION NO. 0002	3. EFFECTIVE DATE 09/14/2026	4. REQUISITION/PURCHASE REQ. NO. 7375939	5. PROJECT NO. (If applicable)		
6. ISSUED BY CG MCAS Cherry Point FACILITIES, ROICC B-87, 748 Roosevelt Blvd. PSC BOX 8006 MCAS CHERRY POINT NC 28533-0012		7. ADMINISTERED BY (If other than item 6.)		Code	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code) AMENDMENT MUST BE ACKNOWLEDGED WITH YOUR PROPOSAL			☒	9A. AMENDMENT OF SOLICITATION Project XK11237, Repair and Upgrade Building 4034, FRCE	
				9B. DATED (SEE ITEM 11)	
			☐	10A. MODIFICATION OF CONTRACT/ORDER NO.	
				10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE			

11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 14. The hour and date specified for receipt of Offers ☒ **is extended** ☐ **is not extended**. Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 8 and 15, and returning 1 copy of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

12. ACCOUNTING AND APPROPRIATION DATA (if required)

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

☐	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14. ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.
☐	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATION CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103 (b).
☐	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
☐	D. OTHER: (specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not ☐ is required to sign this document and return **original** to the issuing office.

14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)

PROJECT XK11237, REPAIR AND UPGRADE BUILDING 4034, Station Marine Corps Air Station Cherry Point, NC

The deadline for PPI submissions HAS PASSED.

The proposal due date of 16 September 2026 by 1500 HAS BEEN CHANGED to 18 September 2026 at 2:00PM.

The purpose of this amendment is to answer pre-proposal inquiries (PPIs) and extend the proposal due date.

See attached.

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR (Same as Item 8)	15C. DATE SIGNED	16B. UNITED STATES OF AMERICA BY	16C. DATE SIGNED
(Signature of person authorized to sign)		(Signature of Contracting Officer)	


Block 14. DESCRIPTION OF AMENDMENT (cont.)

- A. This amendment updates the **Proposal Due Date/Time** section provided in the original Request for Proposal to the following:

Proposal Due Date/Time: 18 July 2026 by 1400 local time

- B. All other contract terms and conditions remain unchanged.

PREAWARD INQUIRY FORM

	SUBMITTED	PAGE	SECTION	PARAGRAPH	QUESTION	ANSWER	AMENDMENT #
1	8/27/2026				Please provide the Government's estimated cost range for this project. This information is requested to determine whether a bid bond will be required and to allow our surety to evaluate the appropriate bonding limits, as the estimated cost range is required for their review. Providing this information in advance will help avoid the unnecessary risk associated with requesting a bid bond on the day of bid submission and ensure sufficient time for the surety to issue the bond, allowing us to comply with the solicitation's Bond Requirements, which require the bid bond to be submitted with the proposal.	Between \$10,000,000.00 and \$25,000,000.00.	0001
2	8/28/2026				Please confirm the Liquidated Damages for this project - \$15,000 per day for phases 1-3 and \$75,000 per day for phase 4.	The numbers for LDs for this project are listed correctly on the RFP.	0001
3	9/3/2026	A-601			Lines generally denote operable. I can't see how or why these openings wouldn't be fixed. Clarification please?	See updated drawing in folder	0001
							
4	9/10/2026	59, 62	Drawing PD401		Drawing sheets PD401 and P-401 indicate reuse of existing rough-ins at certain plumbing fixture locations while also referencing sawcut and patch work for drain piping modifications. Please identify the fixture locations requiring new below-slab drain piping and associated sawcut/patch work for bidding purposes.	Sawcut as required to remove and install sanitary piping as shown on PD401 view 3 and P-401 view 2.	0002
5	9/10/2026	284-293	HM001 Note A		Confirm whether the assumed ACM ceiling tile within the blasting booth (approximately 5,100 SF area shown on Life Safety Plan) is included in the Contract scope for abatement and removal.	The assumed ACM ceiling tile is shown on drawings HM101 and AD104.	0002
6	9/10/2026		HM001 Note 1		The specifications state to assume cleaning 500 SF of gypsum/masonry surfaces and removal of 200 SF of contaminated ceiling tile. Please provide drawing locations identifying these quantities.	Drawings HM101 and HM102 provide the general locations of the stained and mold contaminated SACT.	0002

PREAWARD INQUIRY FORM

	SUBMITTED	PAGE	SECTION	PARAGRAPH	QUESTION	ANSWER	AMENDMENT #
7	9/10/2026		PH101 Phasing Plan Note		Temporary HVAC is required during reroofing adjacent to the occupied Rubber Shop. Please define performance requirements, duration, temperature/humidity requirements, and responsibility for power	Existing Rubber Shop is conditioned by (3) 10 ton heat pumps. Duration is dependent on how long the reroof process takes. Maintain 78 degrees and 50% RH during summer and 68 degrees during winter. Contractor responsible for temporary power.	0002