

	TYPE	LOCATION	HYDRO	Last Insp	COMMENTS / RECOMMENDATIONS
		BUILDING 216			
1	2011ABC	1 st FLOOR HALL BY ELEVATOR	UNK	2026	DUEHYDRO
2	511 ABC	1 st FLOOR ELEVATOR ROOM	UNK	2026	DUEHYDRO
3	511 ABC	1 st FLOOR RM 104	UNK	2026	DUEHYDRO
4	10# ABC	RM 109	UNK	2026	DUEHYDRO
		2ND FLOOR			
5	5# ABC	BY OFFICES	UNK	2026	DUEHYDRO
6	IOI/ABC	BY OFFICES	UNK	2026	DUEHYDRO
7	511 ABC	3RD FLOOR	UNK	2026	DUEHYDRO
8	51/ABC	AT THE JUNCTION	UNK	2026	DUEHYDRO
		BUILDING 301			
9	1011ABC	1 st FLOOR 301 PUMP ROOM	UNK	2026	DUEHYDRO
10	511 ABC	IN 301 HALL	UNK	2026	DUEHYDRO
		BUILDING 302			
11	IOI/ABC	IN 302 HALL	UNK	2026	DUEHYDRO
12	2011 ABC	IN 302 LAB	UNK	2026	DUEHYDRO
13	2011 ABC	IN 302 LAB	UNK	2026	DUEHYDRO
14	2011 ABC	IN 302 WATER ROOM	UNK	2026	DUEHYDRO
15	SI/CO2	RM 104	UNK	2026	DUEHYDRO
16	IOI/ABC	IN ELEVATOR MACHINE ROOM	UNK	2026	DUEHYDRO
17	IOI/ABC	2ND FLOOR HALL	UNK	2026	DUEHYDRO
18	51/ABC	3RD FLOOR AT THE JUNCTION	UNK	2026	DUEHYDRO
		BUILDING 305			
19	511 ABC	IN BUILDING 305 KITCHEN	UNK	2026	DUEHYDRO
		BUILDING 306			
20	IO# ABC	1 st FLOOR ELEVATOR LOBBY	UNK	2026	DUEHYDRO
21	511 ABC	IN 1 st FLOOR ELEVATOR ROOM	UNK	2026	DUEHYDRO
22	5CO2	1 st FLOOR COMPUTER ROOM	UNK	2026	DUEHYDRO
23	2.5#ABC	RM 109 UNDER STAIRS	UNK	2026	DUEHYDRO
24	1011ABC	AT THE JUNCTION	UNK	2026	DUEHYDRO
25	10# ABC	2nd FLOOR IN ELEVATOR LOBBY	UNK	2026	DUEHYDRO
		BUILDING 307			
26	10# ABC	IN HALL	UNK	2026	DUEHYDRO
		MAINTENANCE ARCHIVE			
27	2011 ABC	MAINTENANCE	UNK	2026	DUEHYDRO
28	2011 ABC	MAINTENANCE	UNK	2026	DUEHYDRO
29	IOI/ABC	MAINTENANCE	UNK	2026	DUEHYDRO
30	2011 ABC	MAINTENANCE	UNK	2026	DUEHYDRO
31	20# ABC	MAINTENANCE	UNK	2026	DUEHYDRO
32	20# ABC	MAINTENANCE	UNK	2026	DUEHYDRO
33	20/1 ABC	MAINTENANCE	UNK	2026	DUEHYDRO
35	20# ABC	MAINTENANCE	UNK	2026	DUEHYDRO
35	5#CO2	MAINTENANCE COMM RM	UNK	2026	DUEHYDRO
36	10# ABC	SPARE	UNK	2026	DUEHYDRO

37	10# ABC	SPARE	UNK	2026	DUEHYDRO
38	10# ABC	SPARE	UNK	2026	DUEHYDRO
39	20# ABC	SPARE	UNK	2026	DUEHYDRO
40	5# ABC	SPARE	UNK	2026	DUEHYDRO
CENTRAL PLANT					
41	10# ABC	CENrRAL PLANT	UNK	2026	DUEHYDRO
42	2.5# ABC	CENTRAL PLANr	UNK	2026	DUEHYDRO
43	5#ABC	PUMP RM	UNK	2026	DUEHYDRO
44	10# ABC	TURTLE HOSPITAL	UNK	2026	DUEHYDRO
45	2.5# ABC	BOAT BARN	UNK	2026	DUEHYDRO
46	2.5# ABC	BOAT BARN	UNK	2026	DUEHYDRO
47	2.5# ABC	BOAT BARN	UNK	2026	DUEHYDRO
48	2.5# ABC	BOAT BARN	UNK	2026	DUEHYDRO
WET LAB OFFICE					
49	5# ABC	WET LAB OFFICE	UNK	2026	DUEHYDRO
50	20# ABC	WET LAB OFFICE	UNK	2026	DUEHYDRO
TURTLE BARN					
51	20# ABC	TURTLE BARN	UNK	2026	DUEHYDRO
52	5# ABC	TURTLE BARN	UNK	2026	DUEHYDRO
53	IO# ABC	TURTLE BARN	UNK	2026	DUEHYDRO
54	20# ABC	[N TURTLE RESERCH	UNK	2026	DUEHYDRO
55	20# ABC	[N TURTLE RESERCH	UNK	2026	DUEHYDRO
56	20# ABC	IN TURTLE RESERCII	UNK	2026	DUEHYDRO
57	20# ABC	[N TURTLE RESERCH	UNK	2026	DUEHYDRO
58	10# ABC	[N TURTLE RESERCII	UNK	2026	DUEHYDRO
59	IO# ABC	TURTLE BARN	UNK	2026	DUEHYDRO

REQUIRING REFILLING						
QTY	TYPE	POSITIO N	Location	STATUS	LAST TEST	STATUS
15	5 HI SA40 ABC	STORAG E	MAINT BAY	EMPTY	UNK	NEEDS REFILLED AND TESTED
10	B- 67597294 ABC	STORAG E	MAINT BAY	EMPTY	UNK	NEEDS REFILLED AND TESTED
10	2.5 SA ABC	STORAG E	MAINT BAY	EMPTY	UNK	NEEDS REFILLED AND TESTED
6	MARINE GRADE FIRE EXTINGUI SHER (B-1 OR B2)	BOAT BARN	BOAT BARN	3 FILL, 3 EMPTY	UNK	3 NEED REPLACED, 3 NEED TO BE CHECKED

41 TOTAL NEED REFILLING